


SEW262 Antistatic


100% Polyester Bi-Co with NANO fiber (F9) alu coated




White
Weiss



1,9
Decitex



0,59
mm



0,03
%



260
gram



MD 900N/5cm Length
CD 700 N/5cm cross

FILTER MEDIA DATA

SEW 262 is a 100% Aluminium coated spun bonded filter media that is manufactured from continuous non-woven fibre which do not permit particles to become embedded.

SEW 262 is a strong and high-pressure durable material, and can be used to prevent static charging and increase cleanability.

This Antistatic 100 % Spun bonded media makes pulse cleaning easy.



Dry
Trocken

100 Celsius

Wet
Feuchte

90 Celsius

Air Permeability | 200Pa
Luftdurchlässigkeit | 200Pa

849 m3/m2/hr

Chemical Resistance | Chemische Eigenschaften

	Excellent Sehr Gut	Good Gut	Fair Mässig
Oil/water resistance Öl und Wasserabweisend	X	X	X
Hydrolysis resistance Hydrolysebeständigkeit	X	X	X
Acid resistance Säurebeständigkeit	X	X	X
Alkaline resistance Alkalienbeständigkeit	X	X	X



Certificate No.
ILK-B-33-24-2746

Phone +45 5460 2080

S.E.W. North Filtration A/S * Europavej 11 * DK-4930 Maribo
E-mail: sales@northfiltration.com * www.northfiltration.com * VAT no.: DK 33 49 28 71



**ILK
DRESDEN**



Test report: ILK-B-33-24-2746

Certificate

Number:	2024/02/33/107
Customer:	S.E.W. North Filtration A/S, Europavej 11, DK-4930 Maribo
Test specimen:	100 % Bi-Co Polyester with Nanofibers (F9) Alu coated, inflow side marked by a label
Designation:	SEW262
Manufacturer:	S.E.W. North Filtration A/S, Europavej 11, DK-4930 Maribo
Date of testing:	2024/02/28 – 2024/02/29
Tested in accordance with:	IEC 60335-2-69:2021-04, appx. AA: AA.22.201.1: Filter material test
Assessment:	The filter material "SEW262" meets the requirements of dust class "M" according to IEC 60335-2-69:2021-04 appx. AA for the above mentioned test at a filter surface load of 200 m ³ /(m ² ·h).
Period of validity of the certificate:	Certificate has validity for all filter materials produced until 29 February 2027 , which are identical to the test specimen.

D. Keßlau

Tested and verified by
Dipl.-Ing. Dirk Keßlau

R. Heidenreich

Technical responsibility
Dipl.-Ing. Ralf Heidenreich

Dresden, 11 March 2024

Institut für Luft- und Kältetechnik gemeinnützige Gesellschaft mbH
Bertolt- Brecht- Allee 20 01309 Dresden | Phone: +49-351-4081-5360
Fax: +49-0351-4081-5398 | www.ilkdresden.de


Air permeability		ILK DRESDEN				
Current number: 07032024_1343						
Operator: E. Schmieder, B.Sc.						
Measuring instruments:		Air permeability:		Air permeability tester L14 DR		
Differential pressure:		VelociCalc Multi-Function Ventilation Meter 9565-P, Ser-Nr.: 9565P1637014 (33/939)				
Task:		Determination of air permeability				
Customer:		S.E.W. North Filtration A/S				
Contact:		L. Pedersen				
Sample type:		100% Bi-Co Polyester with Nanofibers (F9) Alu coated				
Date:		2024/03/07				
Test conditions		Pa		delta P		
Air temperature:		21.4 °C				
Barometric pressure:		1008.3 hPa				
Air humidity:		33.8 %				
Designation		MP 1	MP 2	MP 3	MP 4	Mean value
		l/m^2*s				
SEW262 #01		260	225	265	300	263
SEW262 #02		230	245	180	225	220
SEW262 #03		370	180	255	190	249
SEW262 #04		220	195	245	190	213
Mean value [$l/(m^2*s)$]						236
Mean value [$l/(dm^2*min)$]						142
Mean value [$m^3/(m^2*h)$]						849
Signature:		<i>Dirk Keffeler</i>				
LD200_Flächengewicht_Rev.1.6-2024-02-12						

Figure 4 Test protocol air permeability (LD200), SEW262